



De’Nerika Johnson

Director, Purchasing and Supply Services

Dwight Eisenhower HVAC Modernization

SOLICITATION NO. DCP054-24

ADDENDUM NO. (5)

<u>ISSUED BY</u> DEPARTMENT OF PURCHASING AND SUPPLY SERVICES CONSTRUCTION PROCUREMENT OFFICE PRINCE GEORGE’S COUNTY PUBLIC SCHOOLS, UPPER MARLBORO, MARYLAND 20772	<u>ADDENDUM DATE</u> March 20, 2024 Number of Addendum Pages 2	<u>PROPOSAL SUBMISSION DATE</u> March 25, 2024 2:00 P.M., Eastern Standard Time
	<u>IFB No.</u> DCP054-24	<u>IFB ISSUANCE DATE:</u> February 8, 2024
	<u>PROJECT TITLE:</u> <u>Dwight Eisenhower HVAC Modernization Project</u>	

TO ALL PROSPECTIVE OFFERORS AND OTHER RECEIPTS OF SOLICITATION DOCUMENTS

This Addendum is hereby made a part of the Contract Document, which will be the basis of the Contract. This Addendum is issued to modify and/or correct the original Contract Documents issued on February 8, 2024. Prospective Offerors are requested to attach this Addendum to your Contract Documents. Receipt of this Addendum must be acknowledged on the Proposal. Failure to do so may subject the proposer to disqualification.

The following IFB Provision is hereby changed as follows:

Provide updated response to question and documents for Red Book

<https://drive.google.com/drive/folders/1R7ShNA2U6MxrCwCX2YNxzs1vBHOqfpfN?usp=sharing>

Questions Received	Responses
<p>Drawing Sheet C-1 - Please advise if the existing fuel storage tank has any fuel, if so, provide quantities.</p>	<p>Updated Answer: The tank has oil and is currently in use, will be demolished during construction as the design incorporates "new high-efficiency fully condensing boilers". Removal of oil will be coordinated with the PGCPs Environmental Department.</p>

END OF ADDENDUM NO. FIVE (5)